



NOTES:

1. INSTALL W.H.C. 3.5 FT. MINIMUM BELOW EXISTING GRADE UNLESS OTHERWISE SHOWN OR DIRECTED BY THE ENGINEER.
2. PLACE A BRICK UNDER THE CURB STOP AND CURB BOX FOR STABILITY.
3. END OF W.H.C. AT PROPERTY LINE SHALL BE 4'-0" BELOW FINISHED GRADE UNLESS OTHERWISE SHOWN OR DIRECTED BY THE ENGINEER.
4. CORPORATION STOP TO BE LEFT OPEN, CURB STOP CLOSED.
5. FOR CURB STOP INSTALLATION ON A 1 1/2" AND 2" WATER HOUSE CONNECTION USE STANDARD VALVE BOX AND WOOD SUPPORT. SEE DETAIL W/3.00 (IF LOCATED IN A TRAFFIC OR PAVED AREA—COMMERCIAL ONLY).

CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED: *[Signature]* 6/28/95
DIRECTOR OF DEVELOPMENT SERVICES DATE

[Signature] 6/29/95
WATER / SEWER ENGINEER DATE

STANDARD DETAIL

1", 1 1/2" & 2" WATER
 HOUSE CONNECTION FOR
 INSIDE METERS
 'K' COPPER TUBING

REVISIONS:

W
 2.00