



NOTES:

(1) ALL VALVES SHALL BE RESILIENT WEDGE ONLY AWWA C-509.

(2) APPROVED VALVES ARE: KENNEDY KEN-SEAL II, U.S. PIPE METROSEAL 250, MUELLER SERIES A-2360, AND WATEROUS SERIES 500 FOR 12 INCH AND BELOW, AND 16 INCH SHALL BE U.S. PIPE METROSEAL 250.

CHARLES COUNTY GOVERNMENT  
DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED: *[Signature]* 6/29/95  
DIRECTOR OF DEVELOPMENT SERVICES DATE  
*[Signature]* 6/29/95  
WATER / SEWER ENGINEER DATE

STANDARD DETAIL

DETAIL OF GATE  
VALVE & BOX  
16" & BELOW

REVISIONS:

W  
3.00