



NOTES:

1. BACKFLOW PREVENTER(S) FOR WATER FIRE SPRINKLER SYSTEMS SHALL BE:
 - A) 3/4 INCH TO 2 INCH = ASSE 1024 OR COUNTY APPROVED EQUAL
 - B) 2 1/2 INCH AND ABOVE = WATTES 709 ONSY (ASSE 1015) OR COUNTY APPROVED EQUAL.
2. BACKFLOW PREVENTER(S) FOR LANDSCAPE IRRIGATION SYSTEMS SHALL BE:
 - A) 1/2 INCH - 3 INCH = WATTES 009QT (ASSE 1013) OR COUNTY APPROVED EQUAL.
 - B) 3 1/2 INCH AND ABOVE = WATTS 909QT (ASSE 1013) OR COUNTY APPROVED EQUAL.
 - C) PLUMBING PERMIT REQUIRED.
 - D) INSTALLED IN THE INTERIOR.
3. INSTALL A DRAIN FOR THE BACKFLOW PREVENTER(S).

<p>CHARLES COUNTY GOVERNMENT DEPARTMENT OF PLANNING & GROWTH MANAGEMENT</p> <p>APPROVED: <i>Charles Ang</i> 1-18-07 <small>CHIEF OF DEVELOPMENT SERVICES DATE</small></p> <p><i>M. [Signature]</i> 1-18-07 <small>WATER / SEWER ENGINEER DATE</small></p>	<p>STANDARD DETAIL FIRE SPRINKLER & DOMESTIC SYSTEM CONNECTION (INDIVIDUAL/RESIDENTIAL) OUTSIDE METER</p>	<p>REVISIONS:</p> <table border="1"> <tr><td> </td></tr> <tr><td> </td></tr> <tr><td> </td></tr> <tr><td> </td></tr> </table>					<p style="text-align: center;">W <hr style="width: 50px; margin: 0 auto;"/> 1.03</p>