



NOTES:

1. BLOWOFF SHALL BE LOCATED IN THE FIELD AS DIRECTED BY THE ENGINEER'S REPRESENTATIVE.
2. THRUST BLOCK TO BE POURED AGAINST UNDISTURBED EARTH.
3. THE PRICE FOR A BLOWOFF ASSEMBLY SHALL INCLUDE 6 FEET OF PIPE.
4. PROVIDE A LAYER OF ROOFING PAPER BETWEEN PIPE FITTINGS AND CONCRETE.
5. PROVIDE A 3/4 INCH CORPORATION TAP WITH A 3/4 INCH CURB STOP & BOX WITH A 3/4 INCH DRAIN PIPE INTO GRAVEL UNDER DRAIN. ("K" COPPER ONLY)

CHARLES COUNTY GOVERNMENT  
DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED:

*Michael J. ...* 6/29/95  
DIRECTOR OF DEVELOPMENT SERVICES DATE  
*W.L. Hy...* 6/29/95  
WATER / SEWER ENGINEER DATE

STANDARD DETAIL

WATER MAIN BLOWOFF

REVISIONS:

W  
5.01