



NOTES:

1. REFER TO STANDARD DETAIL W6.05 WHEN METER AREA IS ADJACENT TO AN EXTERIOR WALL.
2. METER TO BE SET HORIZONTALLY. RUN WIRE FROM METER TO OUTSIDE FRONT FOR REMOTE READER.
3. NOMINAL DIMENSION:
3" METER: 1-3 FT
4" AND LARGER METER: 1-2 FT
4. METER NOT TO BE SET WITHIN 10' OF ELECTRICAL DISTRIBUTION EQUIPMENT.
5. TURBULENCE COMPENSATOR MIN. 5 PIPE DIA. INLET AND OUTLET.
6. METER BOTTOM TO BE SET BY PLUMBER. COUNTY WILL SET METER HEAD AND OUTSIDE REMOTE. COUNTY ISSUES METER.

CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED:

[Signature] 6/29/95
DIRECTOR OF DEVELOPMENT SERVICES DATE
[Signature] 6/29/95
WATER / SEWER ENGINEER DATE

STANDARD DETAIL

3" AND LARGER
 INDOOR METER
 INSTALLATIONS

REVISIONS:

W
6.06